

DO NOT SCALE. IF IN DOUBT ASK!

25mm x 25mm x 0.7mm MIN THICK CONTINUOUS GALVANISED ANGLE.

150mm OVERLAP OF FIREFLY™ BARRIER FOLDED BACK TO COVER ANGLE.

FIRE RATED FIXING SECURING THE BARRIER TO THE ANGLE AT 600mm CENTRES BEFORE BEING SECURED BY THE FIREFLY™ HIGH TEMPERATURE ADHESIVE.

FIRE RATED FIXINGS SECURING THE ANGLE TO THE SOFFIT AT 250mm CENTRES.

FIRE RATED FIXINGS SECURING THE CLAMPING ANGLE TO THE SUPPORTING ONE AT 250mm CENTRES.

50mm x 50mm x 0.7mm MIN THICK CONTINUOUS GALVANISED ANGLE.

2 BEADS OF FIREFLY™ HIGH TEMPERATURE ADHESIVE.

FIREFLY™ APOLLO LITE™ BARRIER HANGING FROM SOFFIT.

FIRE RATED FIXINGS CLAMPING THE BARRIER AND ANGLES TO EACH OTHER AT 250mm CENTRES.

FIRE RATED FIXINGS SECURING THE BARRIER TO THE ANGLE AT 600mm CENTRES.

FIRE RATED FIXINGS SECURING THE ANGLE TO THE SOFFIT AT 250mm CENTRES.

DETAIL A.

APOLLO LITE™ - TOP FIX

TBA PROTECTIVE TECHNOLOGIES LTD

UNIT 3, Transpennine Trading Estate, Gorrells Way
Rochdale, OL11 2PX, United Kingdom

T: +44 (0)1706 758 817
E: Technical@TBAFIREFLY.com
W: www.tbafirefly.com

ARTIST: JC

APPROVED: DA

DATE: 07/12/2022

SCALE: NTS

DRAWING NO:

A - 002

REVISION: 1

IN SEQUENCE: 1/1

ALL RIGHTS RESERVED. NO PARTS OF THIS DRAWING MAY BE USED REPRODUCED, ALTERED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION OF TBA PROTECTIVE TECHNOLOGIES LTD. WHILST EVERY EFFORT HAS BEEN MADE TO COMPLY WITH THE CURRENT STATUTORY REGULATIONS, IT IS THE USER'S RESPONSIBILITY TO ENSURE THAT THE FINAL DETAILING AND INSTALLATION MEETS THE REQUIREMENTS OF RELEVANT REGULATORY AUTHORITY (OFTEN BUILDING CONTROL). PLEASE CHECK www.tbafirefly.com TO ENSURE THAT YOU ARE USING THE CORRECT AND CURRENT VERSION. COPYRIGHT 2022

