

7

6

5

4

3

2

1

DO NOT SCALE. IF IN DOUBT ASK!

THIS DETAIL IS ONLY FOR SINGLE CABLES UP TO 16mm IN DIAMETER.
FOR BUNCHES, CABLE TRAYS AND TRUNKINGS SEE (A-231, A-232 & A-232B).

A SMALL HOLE UP TO 16mm IS CUT IN THE BARRIER
TO ACCOMMODATE THE PENETRATION.

FIREFLY™ APOLLO LITE™ BARRIER.

FIREFLY™ HIGH TEMPERATURE ADHESIVE
SEALING THE COLLAROLL FLANGE TO THE BARRIER.

FIREFLY™ COLLAROLL WRAPPED
TIGHTLY AROUND PENETRATION.

12mm STAPLES SECURE THE COLLAROLL
TO ITSELF AT 80mm CENTRES.

CABLE.

THIS DETAIL IS FOR INSTALLING CABLES THROUGH A BARRIER.

IF THE CABLE IS ALREADY PRESENT SEE (A-230 OR A-231).

APOLLO LITE™ - SINGLE CABLE PENETRATION

TBA PROTECTIVE TECHNOLOGIES LTD

UNIT 3, Transpennine Trading Estate, Gorrells Way
Rochdale, OL11 2PX, United Kingdom

T: +44 (0)1706 758 817
E: Technical@TBAFIREFLY.com
W: www.tbafirefly.com

ARTIST: JC

APPROVED: KG

DATE: 07/12/2022

SCALE: NTS

DRAWING NO:

A - 230B

REVISION: 1

IN SEQUENCE: 1/1

ALL RIGHTS RESERVED. NO PARTS OF THIS DRAWING MAY BE USED REPRODUCED, ALTERED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION OF TBA PROTECTIVE TECHNOLOGIES LTD. WHILST EVERY EFFORT HAS BEEN MADE TO COMPLY WITH THE CURRENT STATUTORY REGULATIONS, IT IS THE USER'S RESPONSIBILITY TO ENSURE THAT THE FINAL DETAILING AND INSTALLATION MEETS THE REQUIREMENTS OF RELEVANT REGULATORY AUTHORITY (OFTEN BUILDING CONTROL). PLEASE CHECK www.tbafirefly.com TO ENSURE THAT YOU ARE USING THE CORRECT AND CURRENT VERSION. COPYRIGHT 2022



7

6

5

4

3

2

1