



DO NOT SCALE. IF IN DOUBT ASK!

D

C

B

A

1

2

3

4

PLEAT JOINT

FIREFLY™ COLLAROLL TO BE STAPLED WITH 12mm STAPLES AT 80mm MAXIMUM CENTRES

I-BEAM PENETRATIONS

FIREFLY™ APOLLO LITE™ PACKING TO BE INSULATED BARRIER

I-BEAM PENETRATION MANAGEMENT
 BEFORE COLLAROLLING THE PENETRATION(S), FULLY PACK THE VOIDS WITH FIREFLY™ TO 300mm FROM THE BARRIER

FIREFLY™ COLLAROLL

STAPLE THE FIREFLY™ COLLAROLL TO THE BUTT AND PLEAT JOINTS

USE 2 BEADS OF FIREFLY™ HIGH TEMPERATURE ADHESIVE TO ATTACH THE FLANGE TO THE BARRIER

CLOSING STAPLES AT 150mm CENTRES NOMINAL

2 ROWS OF 12mm STAPLES STAGGERED AT 50mm CENTRES

DETAIL 'A' - PLEAT JOINT

2 ROWS OF 12mm STAPLES STAGGERED AT 50mm CENTRES

BUTT JOINT

CLOSING STAPLES AT 150mm CENTRES NOMINAL

DETAIL 'B' - BUTT JOINT

ALL RIGHTS RESERVED. NO PART OF THIS DRAWING MAY BE USED, REPRODUCED, ALTERED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION OF TBA PROTECTIVE TECHNOLOGIES LTD. WHILST EVERY EFFORT HAS BEEN MADE TO COMPLY WITH THE CURRENT STATUTORY REGULATIONS, IT IS THE USER'S RESPONSIBILITY TO ENSURE THAT THE FINAL DETAILING AND INSTALLATION MEETS THE REQUIREMENTS OF RELEVANT REGULATORY AUTHORITY (OFTEN BUILDING CONTROL). PLEASE CHECK www.tbafirefly.com TO ENSURE THAT YOU ARE USING THE CORRECT AND CURRENT VERSION. COPYRIGHT 2019

TBA Protective Technologies Ltd
 Unit 3, Transpennine Trading Estate
 Gorrells Way, Rochdale, OL11 2PX
 United Kingdom
 T: +44 (0)1706 758 817
 E: technical@tbafirefly.com
 W: www.tbafirefly.com



Drawn By: RJ
 Approved By: MPR
 Scale: NTS
 Date: 02/04/2020

Title: FIREFLY™ APOLLO LITE™ I-BEAM PENETRATION
 Drawing No. A/016
 Rev: 1

1

2

3

4

D

C

B

A