

THIS DETAIL IS ONLY FOR BUNCHES OF CABLES UP TO 16mm IN DIAMETER.
FOR CABLE TRAYS AND TRUNKINGS SEE (T-232 & T-232B).

DO NOT SCALE. IF IN DOUBT ASK!

FIREFLY™ TITAN LITE™ BARRIER.

FIREFLY™ HIGH TEMPERATURE ADHESIVE SEALING THE COLLAROLL FLANGE TO THE BARRIER.

FIREFLY™ COLLAROLL WRAPPED TIGHTLY AROUND PENETRATION.

12mm STAPLES SECURE THE COLLAROLL TO ITSELF AT 80mm CENTRES.

CABLE BUNCHING.

THIS DETAIL IS FOR INSTALLING CABLES THROUGH A BARRIER.
IF THE CABLES ARE ALREADY PRESENT SEE (T-231).

TITAN LITE™ - CABLE BUNCHING PENETRATION

TBA PROTECTIVE TECHNOLOGIES LTD
UNIT 3, Transpennine Trading Estate, Gorrells Way
Rochdale, OL11 2PX, United Kingdom
T: +44 (0)1706 758 817
E: Technical@TBAFIREFLY.com
W: www.tbafirefly.com

ARTIST: JC
APPROVED: KG
DATE: 07/12/2022
SCALE: NTS

DRAWING NO:
T - 231B
REVISION: 1
IN SEQUENCE: 1/1

ALL RIGHTS RESERVED. NO PARTS OF THIS DRAWING MAY BE USED REPRODUCED, ALTERED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION OF TBA PROTECTIVE TECHNOLOGIES LTD. WHILST EVERY EFFORT HAS BEEN MADE TO COMPLY WITH THE CURRENT STATUTORY REGULATIONS, IT IS THE USER'S RESPONSIBILITY TO ENSURE THAT THE FINAL DETAILING AND INSTALLATION MEETS THE REQUIREMENTS OF RELEVANT REGULATORY AUTHORITY (OFTEN BUILDING CONTROL). PLEASE CHECK www.tbafirefly.com TO ENSURE THAT YOU ARE USING THE CORRECT AND CURRENT VERSION. COPYRIGHT 2022

